



SEE PLATE NO. 3-10
FOR SIDEWALK DETAILS

NOTES:

1. SEE MnDOT PLATE NO. 7036 FOR A.D.A REQUIREMENTS REGARDING RAMP SLOPE AND TRUNCATED DOME AREA GUIDELINES.
- ② PROVIDE 1/2" EXP. JT.
- ③ TRUNCATED DOME MATERIAL SHALL BE ON THE APPROVED MnDOT MATERIALS LIST, APPROVED BY THE ENGINEER AND COMPLY WITH MnDOT PLATE NO. 7038.
- ④ SEE PLATE NO. 3-02 FOR CONCRETE SILL DETAIL.
- ⑤ UPON APPROVAL BY THE ENGINEER, 1/2" EXP. JT. NOT REQUIRED IF POURED MONOLITHICALLY WITH SIDEWALK.
- ⑥ RAMP LAYOUT AND CONTRACTION JOINTING SUBJECT TO FIELD MODIFICATIONS BY THE ENGINEER.
7. RAMP THICKNESS TO BE 4" CONCRETE – MnDOT SPEC. MIX 3A32.
8. CONCRETE TO CONSTRUCTED ON PROPERLY COMPACTED BASE.

DATE REVISED
05/07/13

**DIAGONAL PEDESTRIAN
CURB RAMP**

PLATE NO.
3-08