



**NOTES:**

1. SEE MnDOT PLATE NO. 7036 FOR A.D.A REQUIREMENTS REGARDING RAMP SLOPE AND TRUNCATED DOME AREA GUIDELINES.
- ② PROVIDE 1/2" EXP. JT.
- ③ TRUNCATED DOME MATERIAL SHALL BE ON THE APPROVED MnDOT MATERIALS LIST AND APPROVED BY THE ENGINEER.
- ④ SEE PLATE NO. 3-02 FOR CONCRETE SILL DETAIL.
- ⑤ 6" WIDE, VARIABLE HEIGHT, VERTICAL CURB (V-CURB) AS FIELD DETERMINED BY THE ENGINEER. V-CURB MAY BE WITHIN OR OUTSIDE THE SIDEWALK LIMITS DEPENDING ON ROW CONSTRAINTS.
- 6 RAMP LAYOUT AND CONTRACTION JOINTING SUBJECT TO FIELD MODIFICATIONS BY THE ENGINEER.
7. RAMP THICKNESS TO BE 4" CONCRETE - MnDOT SPEC. MIX 3A32.
8. CONCRETE TO CONSTRUCTED ON PROPERLY COMPACTED BASE.

DATE REVISED <b>05/07/13</b>	<b>COMBINED DIRECTIONAL PEDESTRIAN CURB RAMP</b>	PLATE NO. <b>3-09</b>
---------------------------------	------------------------------------------------------	--------------------------