



NOTES:

- ① PROVIDE $1/2''$ EXP. JT.
- ② PROVIDE $1/2''$ EXP. JTS. WHERE WALK ABUTS BUILDING WALLS AND RETAINING WALLS.
- ③ PROVIDE $1/2''$ EXP. JTS. AT PROPERTY LINE AND 100 FT. MAXIMUM INTERVALS.
- ④ SEE PLATE NO. 3-02 FOR CONCRETE SILL DETAIL.
- ⑤ CONTRACTION JOINT SPACING SHOULD BE $1.5 "D"$ OR $12'$ WHICHEVER IS LESS.
- ⑥ SEE PLATE NO. 3-08 FOR PEDESTRIAN CURB RAMP DETAILS.
- ⑦ SIDEWALK THICKNESS IS $6''$ THRU DRIVE WITH $6''$ CL.5 BASE.
- ⑧ SEE PLATE NOS. 3-05 & 3-06 FOR CONCRETE DRIVE APPROACH DETAILS.
- ⑨ LONGITUDINAL JOINTS REQUIRED WHEN $"D"=8'$ OR GREATER.
- ⑩ CONCRETE - MnDOT SPEC. MIX 3A32.
- 11. CONCRETE TO BE CONSTRUCTED ON PROPERLY COMPACTED BASE.

DATE REVISED

02/12/14

SIDEWALK DETAILS

PLATE NO.

3-10